Thin Stone Veneer Installation on Cement Board with Vented MTI Edge Metal™

with Vented MTI Edge MetalTM Sure CavityTM (SC 5016 or SC 5032) or Gravity CavityTM (GC 1816 or GC 1832) and Vented Edge MetalTM (VMEM 3168) **Exterior Sheathing** Fiberglass Reinforced Sure Cavity™ fabric to face the weather Building Cement Board Stud Joint Compound 2 Layers Asphalt Impregnated Grade "D" Construction Paper or Code Required WRB Sure Cavity™ (SC 5016 or SC 5032) or Gravity Cavity™ (GC 1816 or GC 1832) Thin Stone Veneer Back-wrap fabric for bug screen Vented Edge Metal™ (VMEM 3168) Thin Veneer, construction paper, and Vented MTI Edge Metal to run down onto foundation a minimum of 2"

MTI details are created from sources deemed to be reliable. However, MTI does not guarantee the accuracy or completeness of any information, nor shall be held responsible for any errors, omissions, or damages arising out of the use of this information. These details are created with the understanding that MTI is providing information but is not attempting to render engineering or other professional service. If such services are required, the assistance of an appropriate profession should be sought. Use MTI materials in strict conformance with local building codes and regulations. Consult local code/code officials prior to installation. It is the buyer's responsibility to ensure that MTI materials are used in strict conformance with local building codes and regulations.

Copyright © Masonry Technology Incorporated, 12/2009, All Rights Reserved.

01TR02WD005